

Compliance Document

No. D 110412 0008 Rev. 00

Holder of Certificate: **ICM A/S**
Petersmindevej 15
5000 Odense C
DENMARK

Product: **Anchor Device**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 028-713199399

Date, 2021-02-11



(Martin Schmied)

Compliance Document

No. D 110412 0008 Rev. 00

Model(s): Cronus M16 DK

Parameters:

Construction:	Anchor Point for max. 3 persons, made of AISI 316L (stainless steel); total dimensions: 126mm x 93mm x 70mm; 8mm thick; 120° angled; including one \varnothing 50mm hole as anchor point for 3 persons and one swivelling ring (made of 2 parts) with \varnothing 16,2mm hole for fixation to steel or concrete structure;
Fixation:	- fixed to steel structure by 1pc. M16 bolt - fixed to concrete structure (C45/55) by 1pc. Hilti HST3-R M16x135 35/15
Extras:	yellow painted
Marking:	- directly laser-engraved on the anchor device: manufacturer logo; date of manufacture; EN 795:2012 Type A = 1person use; CEN/TS 16415:2013 = 3 person-use; type name; article number; WLL; serial number; "read-instruction"-pictogram
Weight:	382 grams

Tested according to:

EN 795:2012
CEN/TS 16415:2013